



Punjab Fire Services (Barnala)



FIRE SAFETY CERTIFICATE ਫਾਇਰ ਸੇਫਟੀ ਪ੍ਰਮਾਣ ਪੱਤਰ

NOC No **201-85809-Fire/64199**

NOC Type: **Renew**

Dated **28-Feb-2024**

Certified that the **SANAWAR INTERNATIONAL SCHOOL** at **DHURKOT ROAD, DHAULA, DISTT. BARNALA** comprised of **0** basements and **1** (Upper floor) owned/occupied by **Sandeep Singh Mann** have complied with the fire prevention and fire safety requirements of National Building Code and verified by the officer concerned of fire service on **28-Feb-2024** in the presence of **Preet Kamal Sharma** (Name of the owner or his representative) and that the building / premises is fit for occupancy group **B** subdivision **1** (As per NBC) for period of **one year** from issue date. Subject to the following conditions.

Issued on **28-Feb-2024** at **Barnala**

ਤਸਦੀਕ ਕੀਤਾ ਜਾਂਦਾ ਹੈ ਕਿ **SANAWAR INTERNATIONAL SCHOOL** ਜੋ ਕਿ **DHURKOT ROAD, DHAULA, DISTT. BARNALA** ਸਮੇਤ 0 ਬੇਸਮੈਂਟ ਅਤੇ 1 (ਉੱਪਰਲੀ ਮੰਜ਼ਿਲ) ਮਲਕੀਅਤ/ਕਾਬਜ਼ਦਾਰ **Sandeep Singh Mann** ਨੂੰ ਅੱਗ ਬੁਝਾਉਣ ਦੇ ਪ੍ਰਭਾਵੀ ਅਤੇ ਬਚਾਅ ਦੇ ਰਾਸ਼ਟਰੀ ਬਿਲਡਿੰਗ ਕੋਡ ਅਨੁਸਾਰ ਜਿਸ ਨੂੰ ਸਬੰਧਤ ਅੱਗ ਬੁਝਾਉ ਅਧਿਕਾਰੀ ਵੱਲੋਂ ਪ੍ਰਮਾਣਿਤ ਕੀਤਾ ਗਿਆ **28-Feb-2024** ਮੌਜੂਦਗੀ ਵਿੱਚ **Preet Kamal Sharma** (ਮਾਲਕ ਦਾ ਨਾਮ ਜਾਂ ਉਸ ਦਾ ਪ੍ਰਤੀਨਿਧੀ) ਅਤੇ ਇਮਾਰਤ / ਬਿਲਡਿੰਗ ਆਬਾਦੀ ਲਈ ਯੋਗ ਹੈ। Occupancy Group **B** subdivision **1** (ਐਨ. ਬੀ. ਸੀ. ਦੇ ਅਨੁਸਾਰ) ਦੇ ਪ੍ਰਭਾਵੀ ਸਮੇਂ ਤੋਂ ਇੱਕ ਸਾਲ ਤੱਕ। ਜਿਸ ਲਈ ਨਿਮਨ ਅਨੁਸਾਰ ਹਦਾਇਤਾਂ ਹਨ।

ਜਾਰੀ ਕਰਨ ਦੀ ਮਿਤੀ **28-Feb-2024** ਕਿੱਥੇ **Barnala** .

1. Fire Safety arrangements shall be kept in working condition at all the times.
ਹਰ ਸਮੇਂ ਅੱਗ ਤੋਂ ਬਚਾਅ ਦੇ ਯੰਤਰਾਂ ਨੂੰ ਚਾਲੂ /ਚੰਗੀ ਹਾਲਤ ਵਿੱਚ ਰੱਖਿਆ ਜਾਵੇ।
2. No, alteration/ addition/ change in use of occupancy is allowed.
ਕਿਸੇ ਵੀ ਤਰ੍ਹਾਂ ਦੇ ਬਦਲਾਅ/ ਵਾਧੇ/ ਕਾਬਜ਼ਕਾਰ ਵਿੱਚ ਬਦਲਾਵ ਦੀ ਮਨਾਹੀ ਹੈ।
3. Occupants/ owner should have trained staff to operate the operation of fire safety system provided there in.

ਉਪਲੱਬਧ ਅੱਗ ਬੁਝਾਉਣ ਦੇ ਯੰਤਰਾਂ ਦੀ ਵਰਤੋਂ ਤੋਂ ਰਹਿਣ ਵਾਲੇ ਲੋਕਾਂ / ਮਾਲਕਾਂ ਨੂੰ ਜਾਣੂੰ ਕਰਵਾਇਆ ਜਾਣਾ ਯਕੀਨੀ ਬਣਾਇਆ ਜਾਵੇ।

4. Fire Officer can check the arrangements of fire safety at any time, this certificate will be withdrawn without any notice if any deficiency is found.

ਫਾਇਰ ਬ੍ਰਿਗੇਡ ਅਧਿਕਾਰੀ ਕਿਸੇ ਵੀ ਵਕਤ ਇਨ੍ਹਾਂ ਸਾਰੇ ਪ੍ਰਬੰਧਾਂ ਨੂੰ ਚੈੱਕ ਕਰ ਸਕਦਾ ਹੈ, ਜੇ ਕਰ ਕੋਈ ਕਮੀ ਪਾਈ ਗਈ ਤਾਂ ਬਿਨਾਂ ਕਿਸੇ ਨੋਟਿਸ ਦੇ ਇਹ ਸਰਟੀਫਿਕੇਟ ਰੱਦ ਸਮਝਿਆ ਜਾਵੇਗਾ।

5. Occupants/ owner should apply for renewal of fire safety certificate one month prior to expiry of this certificate.

ਮਾਲਕ ਜਾਰੀ ਕੀਤੇ ਗਏ ਫਾਇਰ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਦੀ ਮਿਤੀ ਖਤਮ ਹੋਣ ਤੋਂ ਇੱਕ ਮਹੀਨਾ ਪਹਿਲਾਂ ਰੀਨੀਊ ਕਰਵਾਉਣ ਲਈ ਪਾਬੰਦ ਹੋਵੇਗਾ।

*** Above Details cannot be used as ownership proof.**

ਉਪਰੋਕਤ ਦਰਸਾਈ ਗਈ ਜਾਣਕਾਰੀ ਨੂੰ ਮਾਲਕਾਨਾ ਦੇ ਸਬੂਤ ਵਜੋਂ ਨਹੀਂ ਵਰਤਿਆ ਜਾਵੇਗਾ।

* This is digitaly created cerificate, no signatue are needed

ਇਹ ਡਿਜੀਟਲੀ (ਕੰਪਿਊਟਰਾਈਜ਼ਡ) ਤਿਆਰ ਕੀਤਾ ਗਿਆ ਸਰਟੀਫਿਕੇਟ ਹੈ, ਜਿਸ ਵਿੱਚ ਦਸਤਖਤ ਦੀ ਕੋਈ ਲੋੜ ਨਹੀਂ ਹੈ।

[Inspection Report by Fire Officer](#)



PERFORMA FOR INSPECTION REPORT REGARDING PREVENTION OF FIRE AND SAFETY MEASURES (High rise/multi-storey buildings, hospitals, nursing homes, corporate offices, factories and hazardous storage)		
Date of Inspection ...27/02/2024		
Sr. No.	Details / Checkpoints	Details of the Building / premises / fire safety measures
1	Name of the building / premises (Location / Address)	SANAWAR INTERNATIONAL SCHOOL, DHURKOT ROAD, DHAULA, DISTT. BARNALA
2	Name & Address of the owner with contact no. (s)	Preet Kamal Sharma (7009450592)
3	Name & Address of the Occupier (s) with contact no. (s)	Preet Kamal Sharma (7009450592)
4	Total area of the premises (m2)	10940 m2
5	Total Covered area (m2)	971 m2
6	Height of the building from ground level (Mtrs.)	07 Mtr.
7	Number of basements & its area	Not Applicable
8	Number of sanctioned floors	Ground + One Upper Floor
9	Number of actual floors	Ground + One Upper Floor
10	Parking area (m2)	50
11	Details of surrounding properties a) Front Side b) Left Side c) Right Side d) Back side	As per Drawing
12	Number of Main Gates with size	1 Nos.
13	Number of fire extinguishers installed in the building on each floor with capacity, type with ISI Marking number and date of manufacturing	12 Nos. FE
14	Detail of Hose reel on each floor indicating size and length of rubber pipe	Hose Reel on each floor
15	Details of wet rises, No. of Landing valve, delivery hose, pipe and hose cabinet on each floor	NOT APPLICABLE
16	No. of yard hydrant, with detail	NOT APPLICABLE
17	Whether basement is being used for parking, storage or office. Has the basement sprinkler system? Give all details	NOT APPLICABLE
18	No. of manual fire alarm installed in the building	NOT APPLICABLE
19	Details of automatic fire detection system P.A system provided in the building	NOT APPLICABLE
20	Details of Control Panels	NOT APPLICABLE
21	Details of Water storage capacity underground / overhead with size of tank	5 KL Water Tank

22	Detail of fire pumps with head	450 LPM Capacity
----	--------------------------------	------------------

Owner's Checklist

Error

Failed to load PDF document.

Reload

Print

Print Certificate

**Please Download and keep the print of Inspection Report and Owner's Checklist also,
These documents should be produced on demand along with NOC**